A8.2 EMERGENCY RESPONSE PLAN

Return to MAIN Menu

ENTITY: [Company or Municipality Name]

SYSTEM: [Area or Zone]

FACILITY	PROCESS	PROCEDURE	EMERGENCY EVENT					RESPONSE or MEDIATION					
			Emergency Action Ref. #	Event	Event Type	Failure Indicated or Characterized by:	Action or Failure Effect on System or Property	Necessary Response(s) to Emergency	Beginning Line of Authority (Person in Charge)	Other Resources and/or Supplies Needed	Activate Call List #	NOTES (including Effect of proper response)	File Ref.
A. New Well (1b)													
	1. Pump												
		a. Mechanical Operation											
			256	Pump Control Valve fails to Close.	Emergency	Water is not pumped into system.	System will rapidly loose water.	1. Shut down pump and check for excessive well draw-down.	DWE	Well Probe or manual draw-down test.	**4**	See the attached referenced diagram.	Diagram 452
								2. Manually close auxilary valve # 31-53 while starting pump.	DWE				
			257	Surge Anticipator Fails open and does not close after relief.	Critical	Rapid Loss of Atkinson Reservoir Level and loss of system pressure.	Rapid loss of water and possible property damage from flooding.				**3**		

© Copyright 2005 GeoAnalytica, Inc. All rights reserved.